

Certificate of Compliance

Certificate: 2337609

Master Contract: 250966

Project: 2337609

Date Issued: August 31, 2010

Issued to: **Accendo Electronics Ltd.**
 160 Gibson Drive, Unit 9 Markham,
 Ontario L3R-3K1
 CANADA

Attention: Mr. Les Poroszlay

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: 
 Alvin Kuang

PRODUCTS

CLASS 5411 03 – High Intensity Discharge Lamp Ballasts
 CLASS 5411 83 – High Intensity Discharge Lamp Ballasts – Certified to US Standards

Electronic HID Ballasts, electronic type with remote dimmer control function, 50/60Hz.

Models	Input Voltage (V)	Input Current (A)	Open Circuit Voltage (V)	Lamp Type
B50W-240M	120-240V	0.46A/0.23A	150	1-50W/HPS or 1-50W/MH
B50W-277M	277V	0.20A	150	1-50W/HPS or 1-50W/MH
B70W-240M	120-240V	0.64A/0.32A	150	1-70W/HPS or 1-70W/MH
B70W-277M	277V	0.28A	150	1-70W/HPS or 1-70W/MH
B100W-240M	120-240V	0.92A/0.46A	150	1-100W/HPS or 1-100W/MH
B100W277M	277V	0.40A	150	1-100W/HPS or 1-100W/MH

Certificate: 2337609

Project: 2337609



Master Contract: 250966

Date Issued: August 31, 2010

B150W-240M	120-240V	1.4A/0.7A	150	1-150W/HPS or 1-150W/MH
B150W-277M	277V	0.6A	150	1-150W/HPS or 1-150W/MH
B200/250W-240M	120-240V	2.3A/1.1A	150	1-250W/HPS or 1-250W/MH
F200/250W-240M	120-240V	2.3A/1.1A	150	1-250W/HPS or 1-250W/MH
B200/250W-277M	277V	1.0A	150	1-250W/HPS or 1-250W/MH
F200/250W-277M	277V	1.0A	150	1-250W/HPS or 1-250W/MH
B150W-347M	277-347V	0.6A/0.48A	150	1-150W/HPS or 1-150W/MH
B200/250W-347M	277-347V	1.0A/0.79A	150	1-250W/HPS or 1-250W/MH
F200/250W-347M	277-347V	1.0A/0.79A	150	1-250W/HPS or 1-250W/MH
B575W-277M	240-277V	2.6A/2.3A	150	1-575W/MH
F575W-277M	240-277V	2.6A/2.3A	150	1-575W/MH
B600W-277M	240-277V	2.8A/2.4A	150	1-600W/HPS or 1-600W/MH
B400W-240M	120-240	3.7A/1.8A	150	1-400W/HPS or 1-400W/MH
B400W-277M	277	1.6A	150	1-400W/HPS or 1-400W/MH
B575W-240M	120-240V	5.3A/2.6A	150	1-575W/MH
F575W-240M	120-240V	5.3A/2.6A	150	1-575W/MH
B600W-240M	120-240V	5.5A/2.8A	150	1-600W/MH or 1-600W/HPS
B750W-277H	240-277V	3.4A/3.0A	150	1-750W/HPS
B575W-347M	277-347V	2.3A/1.8A	250	1-575W/MH
F575W-347M	277-347V	2.3A/1.8A	250	1-575W/MH
B750W-347M	277-347V	3.0A/2.4A	250	1-750W/MH
B1000W-347M	277-347V	4.0A/3.2A	250	1-1000W/HPS or 1-1000W/MH
B1000W-240V-M	240V	4.6A	250	1-1000W/HPS or 1-1000W/MH
B750W-240V-MH	240V	3.4A	250	1-1000W/MH

Note:

1. Certified for use only in a luminaire where the suitability of the combination is to be evaluated by CSA International.
2. The output cord, output leads, lampholder, lampholder leads and associated insulating barriers have not been investigated for suitability in regards to temperature and accessibility in the end product

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.74-96 - Equipment for use with electric discharge lamps
UL 1029 (5th Edition) - High-Intensity-Discharge Lamp Ballasts